

## EU DECLARATION of CONFORMITY



**KSR Lighting Ltd**

Optimum House, Beeding Close  
Southern Cross Trading Estate  
Bognor Regis, West Sussex, PO22 9TS



**Declares that under our sole responsibility the Product Range**

**KSRSF401, 403 & 405**

is in conformity with the provisions of the following EU directives and regulations, including all amendments, and with national legislation implementing these directives:

|             |  |                     |
|-------------|--|---------------------|
| <b>LVD</b>  | Low Voltage Directive                    | <b>2014/35/EU</b>   |
| <b>EMC</b>  | Electro Magnetic Compatibility Directive | <b>2014/30/EU</b>   |
| <b>ERP</b>  | Energy Related Products Directive        | <b>2019/2020/EU</b> |
| <b>RoHS</b> | Restriction of Hazardous Substances      | <b>2015/863/EU</b>  |

**The following harmonised standards have been applied**

**EE(S) R**

BS EN 60598-1:2021+A11:2022  
BS EN 60598-2-22:2022

Luminaires – Part 1: General requirements and tests  
Luminaires – Part 2: Luminaires for Emergency Lighting

BS EN IEC 60598-2-1:2021

Luminaires. Particular requirements. Specification for fixed general purpose luminaires

BS EN 62493:2015+A1:2022

Assessment of Lighting Equipment Related to Human Exposure to Electromagnetic Fields

**RoHS**

BS EN 63000

Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances

**EMCD**

BS EN 61547:2009

Equipment for general lighting purposes. EMC immunity requirements

BS EN 55015:2013+A1:2015

Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment

BS EN 61000-3-2:2019+A1:2019

Electromagnetic compatibility (EMC). Limits. Limits for harmonic current emissions

BS EN 61000-3-3:2013+A2:2021

Electromagnetic compatibility (EMC). Limits. Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems

Authorised signatory:

Name: Jon Callander  
Position: Managing Director  
Date: 25/05/2024  
Place of issue: As above

**RoHS** 