



Certificate Number: KSR98100-104-190521-2021-CC

Date of Issue: May 2021

Manufacturer: KSR Lighting Ltd, Unit E, Hazleton Interchange,
Lakesmere Road, Waterlooville, Hampshire,
PO8 9JU.

Product: Self-test Emergency Lighting Range

Model: KSR98100, KSR98101, KSR98102, KSR98103 &
KSR98104

Range Name: Navara Self-Test Emergency Lighting Range:
Remote EM Pack, Exit Box, Exit bulkhead, Twin
Spot & 4in1 Exit Sign

Test Standard Applies: BS EN 60598-1:2021,
BS EN 60598-2-22:2014+A1 2020

In Conformity with: LVD – Low Voltage Directive 2014/35/EU
EMC – Electromagnetic Compatibility Directive 2014/30/EU
ERP – Energy Related Products Directive 2019/2020/EU
RoHS – Restriction of Hazardous Substances 2015/863/EU

This certificate applies specifically to the products/models listed above, all products/models listed above are designed, built, and tested in accordance with the relevant standards applied. All products/models listed are certified to carry the CE mark in accordance with European Regulations and the UKCA mark for conformity assessment.

For and on Behalf of KSR Lighting

Jonathan Callander

Managing Director

RoHS **UK
CA** **CE**